www.gira.com

Button interface, 4-gang Standard for KNX

GIRA Data sheet



| Specification | Order No. | Packing unit | PS | EAN |
|---------------|-----------|--------------|----|---------------|
| | 5184 00 | 1/5 | 06 | 4010337110156 |

Features

General

- According to the variant, two, four or eight independent channels that operate as inputs or as outputs depending on the ETS parameterisation.
- Common reference potential for all channels.
- Outputs: Connection of LED. Short-circuit-proof, protected against overload and polarity reversal. Parallel switching of outputs possible, for consumers with higher current requirements.
- Inputs: Pulse current to prevent contact contamination due to formation of an oxide layer on the connected contacts.
- Channels can be activated and deactivated individually.

Possible parameterisation depending on the selected channel function

- Contact type can be set.
- Switching: Command when pressed and/or released can be set (No reaction; Switch on; Switch off; Switch over).
- Forced setting: Command when pressed and/or released can be set (No reaction; Forced active, Switch on; Forced active, Switch off; Forced inactive).
- Dimming and colour temperature: The command when pressed, time between switching and dimming, dimming in different steps, telegram repetition if pressed for a long time and sending of a stop telegram at the end of pressing can be set.
- Blind/shutter/awning/roof window: Command when pressed and command sequence can be set.
- Value transmitter: Data point type, value range and value can be set. As an option, the value adjustment can be activated by pressing and holding the button.
- Scene auxiliary unit: Scene number can be retrieved or switched by briefly pressing the button. If the button is pressed and held, the memory function is executed as an option.
- Short and long button press: Up to two telegrams can be sent to the KNX by pressing a button. The transmission behaviour can be set and the time for short and long actuation can be adjusted. The mode of operation of the channels can be set separately.
- Room temperature controller operating point: The mode of operation (operating mode switch-over, forced operating mode switch-over, presence function and setpoint temperature shift) can be set.
- Behaviour after bus voltage recovery can be set.
- Disable function can be set.
- Cyclic transmission can be set.

GIRA Data sheet

catalogue.gira.com

© Copyright by Gira Giersiepen GmbH & Co. KG All rights reserved

www.gira.com

| Technical data | |
|---|-------------------------------------|
| KNX medium: | TP256 |
| Output voltage: | DC 3.3 V SELV |
| Output current per channel: | max. 3.3 mA |
| LED current: | 1.6 mA per output |
| Length cable set: | 25 cm, can be extended to max. 10 m |
| Protection class: | IP20 |
| Protection class: | III |
| Ambient temperature: | -5 °C to +45 °C |
| Number of inputs: | 4 |
| Dimensions (LxWxH): | 43.0 x 28.5 x 15.4 mm |
| KNX current consumption: | 4 to 9 mA |
| KNX: | Connection and junction terminal |
| Input cable: | 5-wire cable set |
| | |
| Notes | |
| | |
| | |
| | |
| Scope of supply | |
| - Connection and junction terminal for KNX - 5-wire cable set | |
| | |