© Copyright by Gira Giersiepen GmbH & Co. KG All rights reserved

www.gira.com

Basic Q smoke alarm device

GIRA Data sheet



Specification	Order No.	Packing unit	£/piece without VAT	PS	EAN
pure white glossy	1149 02	1	32.79	03	4010337016694

Increased quality criteria and technical advancements in smoke alarm devices are indicated on the market with the new Q test mark. The new Q-Label is an autonomous, manufacturer-independent quality mark for high-quality smoke alarm devices which undergo special testing for long-term use. The latest generation of Gira smoke alarm devices fulfil the criteria of the new Q-Label quality mark. The smoke alarm devices operate based on the photoelectric scattered light principle without radioactive particles. The smoke alarm devices detect smoke accumulation early and emit a warning signal before the concentration of smoke can become hazardous to people. Alerting occurs via a loud pulsing alarm tone and a flashing LED.

Features

- Only for use in private residential units or residential-like areas in accordance with DIN 14676.

Q-Label

- Tested durability and reduction of false alarms.
- Increased stability, e.g. against external factors.
- Permanently installed battery with a service life of up to 10 years.
- designAaccording to DIN EN 14604.
- KRIWAN approval.
- Integrated function button for function test.
- Fault indication.
- Weak battery indication.

Technical data

Power supply: Via smoke alarm device battery

Battery life: up to 10 years (following activation)

Acoustic signal: Alarm: at least 85 dB (A)

Optical signal: Ring indicator (red LED)

Ambient temperature: -5 °C to +55 °C

GIRA Data sheet

catalogue.gira.com

© Copyright by Gira Giersiepen GmbH & Co. KG All rights reserved

www.gira.com

Installation height: Max. 6 m

Protection class: IP30

Area of application: DIN 14676

Standards: DIN 14604

- design:

Batteries

- Type: 3 x CR123A - UN no.: 3091

Dimensions

- Housing: Ø 125,0 H 38,5 mm